From:
 Trey Driscoll

 To:
 Bennett, Jim

 Cc:
 Steve Dickey

Subject: RE: Cumulative Groundwater Demand Analysis Boulevard Area

Date: Monday, July 09, 2012 2:10:57 PM

Jim,

Thank you for looking into this.

Project update Tierra del Sol (Well B)

We are setting the 50 foot, 10-inch sanitary seal this week and reaming the borehole to 10 inches to allow for lining with a casing. I will have a proposed well test plan submitted to you shortly for this well.

Cheers,

Trey

From: Bennett, Jim [mailto:Jim.Bennett@sdcounty.ca.gov]

Sent: Monday, July 09, 2012 8:51 AM

To: Trey Driscoll

Subject: RE: Cumulative Groundwater Demand Analysis Boulevard Area

Trey,

I looked in our database and found soil boring permits, monitoring well permits and destruction permits, but no production well permits for the four APNs provided below.

Jim Bennett, P.G. #7707, CHG#854 Groundwater Geologist

County of San Diego

Department of Planning and Land Use 5201 Ruffin Road, Suite B, M.S. O-650 San Diego, CA 92123-1666

Office: 858-694-3820, Fax: 858-694-3373

From: Trey Driscoll [mailto:tdriscoll@dudek.com]

Sent: Sunday, July 08, 2012 3:33 PM

To: Bennett, Jim

Subject: Cumulative Groundwater Demand Analysis Boulevard Area

Jim,

Does the County have any well records for assessor's parcel numbers (APN) 612-091-1300, 612-030-1800, 613-030-2800 or 613-030-3500 (see attached map). There are several wells with 9-inch conductor casings located on the property with unknown production capacities.

Cheers,

Trey

TREY DRISCOLL, PG, CHG

PROJECT MANAGER/ HYDROGEOLOGIST

DUDEK

ENGINEERING + ENVIRONMENTAL 605 THIRD STREET ENCINITAS, CALIFORNIA 92024 T 760.479.4154 F 760.942.5206 C 760.415.1425 WWW.DUDEK.COM

PLEASE NOTE: Dudek & Associates uses an email filter to clean viruses and filter Spam. Please take the time to verify receipt of any important or time-sensitive email sent to us.